DOCK	- Wooden/ - 2" x 6" Fir, red cedar, redwood, cypress, plastic eastern white cedar or plastic.
	- Max. width - 2.0 meters (6.5 ft.). Of ramps/ walkways
	- Max. width - 3.0 meters (10ft.). of any other portion of <i>structure</i>
	- Max. Length - 30 meters (98ft.) maximum measured from low water mark
	 Finish Painted to match existing wharves and piers All metal to be rust primed or galvanized.
	- Hardware - Galvanized.
	- Stringers - 2" x 6" minimum – Fir, red cedar, redwood, cypress, eastern white cedar or plastic.
BOAT LIFT	- Docks may be equipped with a boat lift in Units 11 and 12 provided the boat lift is designed to lift a maximum 6.7 meters length boat. Roof or covers are not permitted.
BASE STRUCTURES	- To Best Engineering Practices
FORESHORE TIE	- To Best Engineering Practices
UPRIGHT SUPPORTS	- To Best Engineering Practices - No further than 4.9 meters (16 ft.) apart, with the base of the deck supported on both sides – In rare cases pilings may have to be greater than 4.9 meters (16 ft.). If this is the situation the District will assess this on a case by case basis.

SCHEDULE OF THE REQUIREMENTS FOR THE STRUCTURE, DESIGN AND APPEARANCE OF DOCKS IN THE DISTRICT OF PEACHLAND

NOTE: Solid core structures, filling, or dredging are not permitted





These drawings are not to scale. They are examples.